



PRODUCT TESTING SERVICE

100 Clemson Research Blvd. Anderson, SC 29625 Tel (864) 646-TILE Fax (864) 646-2821
TCNA TEST REPORT NUMBER: TCNA-053-08 PAGE: 1 OF 1

TEST REQUESTED BY: Florim Ceramiche SpA
Attn: Allesandro Villa
Via Canaletto 24
41042 Fiorano (Mo)
Italy


TEST SUBJECT MATERIAL: Identified by client as: Architech Pumice Matt 24 x 24
#721157

TEST DATE: 2/15/08-3/6/08

TEST PROCEDURE: ASTM C1026: "Standard Test Method for Measuring the Resistance of Ceramic Tile to Freeze-Thaw Cycling"
-Ten specimens were tested.
-The specimens were subjected to fifteen cycles of freeze-thaw consisting of freezing the tiles at 0°F for eight hours then thawing the tiles in water at 74°F.

TEST RESULTS: All ten (10) specimens showed **no** visible evidence of freeze-thaw damage after completing fifteen (15) cycles of freeze-thaw.


Katelyn Simpson
Laboratory Engineer


Date